# Data Sheet | Item Number: 285-435

Jumper; insulated; gray

https://www.wago.com/285-435





Color: ■ gray

## Electrical data

## Ratings per IEC/EN

Rated current 85 A

Physical data	
Width	16 mm / 0.63 inches
Height	13.6 mm / 0.535 inches
Depth	40.4 mm / 1.591 inches
Jumper assignment	1-2

Material data	
Note (material data)	Information on material specifications can be found here
Color	gray
Fire load	0.076 MJ
Weight	7.8 g

Commercial data	
Product Group	1 (Rail Mounted Terminal Blocks)
eCl@ss 10.0	27-14-11-40
eCl@ss 9.0	27-14-11-40
ETIM 8.0	EC000489
ETIM 7.0	EC000489
PU (SPU)	50 (25) pcs
Packaging type	Вох
Country of origin	DE
GTIN	4044918396400
Customs tariff number	85366990990

## Data Sheet | Item Number: 285-435

https://www.wago.com/285-435




#### **Environmental Product Compliance**

RoHS Compliance Status Compliant, No Exemption

## Approvals / Certificates

## General approvals







**Approval** Standard **Certificate Name** C22.2 154112 DEKRA Certification B.V.

Approval Standard **Certificate Name** UL 60079 E185892 (AEx eb II C resp. Underwriters Laboratories Ex eb II C) Inc.

#### **Downloads**

## **Environmental Product Compliance**

#### Compliance Search

**Environmental Product** 

Compliance 285-435

Documentation			
Bid Text			
285-435	19.02.2019	xml 2.48 KB	<u>↓</u>
285-435	04.01.2018	doc 23.50 KB	$\downarrow$

CAD/CAE-Data	
CAD data	CAE data
2D/3D Models 285-435	EPLAN Data Portal 285-435
	WSCAD Universe 285-435
	ZUKEN Portal 285-435

## Data Sheet | Item Number: 285-435

https://www.wago.com/285-435



#### **Installation Notes**

## Commoning



Commoning adjacent terminal blocks using a centrally positioned push-in jumper



Slide the marking strip laterally to remove the jumper.

## Commoning



The following 285 Series Through Terminal Blocks can be commoned with 283 Series Through Terminal Blocks: 285-635 or 285-634 with 283-601 or 283-604 (terminal blocks with side marking, wight way were seeding early).

visit www.wagocatalog.com) Adjacent jumper required: 285-435

Please note that the nominal current of the adjacent jumper must not exceed 63 A.

Subject to changes. Please also observe the further product documentation!